

DIVISION OF INDUSTRY SERVICES
Plumbing Product Review
P.O. Box 2658
Madison, Wisconsin 53701-2658
TTY: Contact Through Relay

Scott Walker, Governor Dave Ross, Secretary

September 26, 2014

DIAMOND WATER CONDITIONING JOHN GRIESBACH / DAN SCHLENZ N1022 QUALITY DRIVE PO BOX 170 GREENVILLE WI 54942

Re: Description: WATER TREATMENT DEVICE - SOFTENER/CATION EXCHANGE

Manufacturer: DIAMOND WATER CONDITIONING

Product Name: RUSTMASTER

Model Number(s): DRS4-EM-15-RM, DRS4-EM-24-RM, DRS4-EM-32-RM, DRS4-EM-33-RM,

DRS4-EM-49-RM AND DRS4-EM-66-RM

Product File No: 20140271

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters SPS 382 through 384, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of September 2019.

This approval is contingent upon compliance with the following stipulation(s):

- This product has undergone sufficient testing to document the product's ability to reduce only those
  contaminants and/or substances as specified in this approval letter when the product is installed and maintained
  in strict accordance with the manufacturer's published instructions.
- Where the Department of Natural Resources (DNR) has jurisdiction, a written approval may be required prior to installation of this product in a water supply system to reduce the concentration of a contaminant that exceeds the primary drinking water standards contained in ch. NR 809, Wis. Admin. Code, the enforcement standards contained in ch. NR 140, Wis. Admin. Code, or for a water supply system that is subject to a written advisory opinion by the DNR. For more information contact the DNR Section of Private Water Systems, P.O. Box 7921, Madison, WI 53707, telephone (608) 267-9787.
- If these approved devices are modified or additional assertions of function or performance are made, then this
  approval shall be considered null and void, unless the change is submitted to the department for review and the
  approval is reaffirmed.
- These cation exchange water softeners shall be sized, installed, programmed and maintained such that wastewater volumes, total dissolved solids and chloride discharges are minimized.
- The department does not recommend the use of water softeners for reducing dissolved iron concentrations in excess of 3.0 mg/l. This is because applying water softeners in this way sacrifices long-term water softener performance and efficiency. The use of water softeners for reducing dissolved iron concentrations exceeding 3.0 mg/l also generates excessive, and otherwise avoidable, quantities of chloride and dissolved solids which are subsequently discharged to ground and/or surface water supplies. Once present in ground and/or surface water supplies, chloride and dissolved solids tend to remain in the water resource and may travel great distances from the original point source. Presently, there are no economically viable methods to remove chloride and dissolved solids from water supplies because available technologies generate waste streams of their own, further concentrating the problem. It has been established by the Wisconsin Department of Natural Resources that chloride is chronically toxic to representative aquatic organisms, including forage and sport fish, at 395 mg/l, and acutely toxic at 757 mg/l.

SBD-10564-E (N.10/97) File Ref: 14027102.DOC

Diamond Water Conditioning September 26, 2014 Page 2 of 3

Product File No: 20140271

• These devices are not approved for the reduction of bacterial, colloidal or organically bound forms of iron.

The water must be tested to speciate the iron present to determine if these devices can provide adequate treatment.

Based on testing data submitted to and reviewed by the department, this approval recognizes that these plumbing products will reduce the concentration of contaminants as specified on pages 1 through 2 of this letter.

## WATER SOFTENING CAPABILITIES PRODUCT FILE NUMBER 20140271 TABLE 1 OF 1

Model Numbers DRS4 Series Metered	Iron Capacity @ 9 lbs./ft. <sup>3</sup> ppm-gal*	Capacity*				
		Rating 1		Rating 2		Flow Rate
		Grains	Pounds	Grains	Pounds	gpm @ psig
DRS4-EM-15-RM	3,850	13,500	5.0	15,300	7.0	4.4 @ 15
DRS4-EM-24-RM	5,800	21,700	7.5	24,600	10.5	5.2 @ 15
DRS4-EM-32-RM	7,700	29,000	10.0	32,800	14.0	6.3 @ 15
DRS4-EM-33-RM	7,700	29,000	10.0	32,800	14.0	8.6 @ 15
DRS4-EM-49-RM	11,600	43,500	15.0	49,100	21.0	6.6 @ 15
DRS4-EM-66-RM	19,300	58,000	20.0	65.500	28.0	8.2 @ 15

<sup>\*</sup> The softener capacity rating is based on grains of hardness, due to calcium and magnesium cations, removed (as calcium carbonate) while producing soft water between successive regenerations and is related to the pounds of salt required for each regeneration. The tests run to generate the data for table 1 were conducted in accordance with NSF Standard 44 (hardness reduction) and NSF Standard 42 (dissolved iron reduction). The maximum dissolved iron influent concentration is 5 mg/l.

◆ ppm-gal = parts per million - gallons. To determine the estimated onsite capacity, divide the "Iron Capacity" for a given model by the onsite dissolved iron concentration. For example, using model DRS4-EM-15-RM with an onsite dissolved iron concentration of 5 ppm would result in an estimated capacity of 3,850 ppm-gal/5 ppm dissolved iron = 770 gal. estimated capacity @ a 9 lb. salt dosage.

This device was tested under controlled laboratory, or field, conditions. The actual performance of this device for a specific end use installation will vary from the tested conditions based on local factors such as water pressure, water temperature and water chemistry.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Glen W. Schlueter
Environmental Engineer - Plumbing Product Reviewer
Depart of Safety and Professional Services
Division of Industry Services
Bureau of Technical Services
(608) 267-1401 Phone
(608) 267-9723 Fax
glen.schlueter@wi.gov E-mail